



GUJARAT BIOTECHNOLOGY UNIVERSITY

**GIFT City, GIFT City Road,
Shahpur Village, Gandhinagar- 382355**

Email: info-gbu@gujarat.gov.in

Website: www.gbu.edu.in/



Response to Pre-Bid Queries

**Request for Proposal (RFP) for appointment of Contractor for Residential Facilities at Gujarat
Biotechnology University, Gandhinagar**

E-Tender No.: 01 of 2023-24, Tender ID: 9814

| S. No | Page No. | Section of the Tender | Query/Clarification Sought | Response/Clarification |
|-------|----------|---|--|--|
| 1. | | BOQ Item No. 166 | We request to please share modular kitchen drawing with measurement & size with all required details because price of modular kitchen rate is very different. | Document added separately. Refer Drawing No.: 202210-GBU-H1-H2-S3-AD-001 |
| 2. | | BOQ Item No. 167 | In this item, so many different - different items will provide. Therefore, please provide make, mode, capacity, size, length and required drawings. | Document added separately. Refer Drawing No.: 202210-GBU-H1-H2-S3-AD-002 |
| 4. | | BOQ Item No. 227 | As per Item no 227 & 228, in description it is mentioned that rising mains shall include tap of box, MCCB & EFU – kindly provide details for considering this or provide SLD for the Rising mains. | SLD Attached Already uploaded with Drawing Nos. 202210-GBU-S4-EL-SLD-001 - For Hostel Block 202210-GBU-S4-EL-SLD-001 - For Housing Block |
| 5. | | BOQ Item No. 228 | | |
| 6. | | BOQ Item No. 266 | Unit given in Meter kindly provide size or change unit in KG | 25mm X 5 mm |
| 7. | | BOQ Item No. 267 | Unit given in Meter kindly provide size or change unit in KG | 25mm X 5 mm |
| 8. | | BOQ Item No. 318 | In BOQ total CCTV quantity is asked as 163 but VMS asked for 900 Cameras. So, do we need to consider VMS for 163 Cameras or 900 Cameras? | As there will be more buildings in future in the campus so VMS were asked for 900 cameras but for now you consider 200 Cameras VMS but it should be scalable upto 2000 cameras |
| 9. | | BOQ, Technical Specifications and Approved Makelist - ELV | As major items are from SOR, BOQ description and technical specifications are not matching. Also, approved make list are not complying with BOQ description and technical specifications. | Query asked is of general nature. Needs specific Items. |

| S. No | Page No. | Section of the Tender | Query/Clarification Sought | Response/Clarification |
|-------|----------|--|---|---|
| | | | <p>In general scenario BOQ is supersede the all other documents.</p> <p>Kindly confirm.</p> | |
| 10. | | BOQ Item No. 300 and 301 | <p>As Fire Alarm System is asked of approved LPCB and VDS, Fire Alarm approved makes (LPCB and VDS) like Notifier, Siemens, Edwards, etc will not have Fire Telephone Jack and Fire Telephone handset.</p> <p>So kindly confirm what standards to follow.</p> | In addition to LPCB / VDS standards UL & EN standards are also accepted |
| 11. | | As Per NIT & Corrigendum-1 | <p>This time is very short time because speed post or RPAD take time Minimum 4or5 days & courier take time 3or4 days.</p> <p>Therefore, we request to please consider 7-days after online submission for offline submission documents & also allowed personal submission.</p> | Refer Corrigendum -3 |
| 12. | 25 | 2.2.2 Pre Qualification for Bidder Evaluation Criteria | Request to revise this clause and average monthly financial progress of at least Rs 4 Crs may please be considered instead of Rs 5 Crs to enhance the competition in bid process. | Refer Corrigendum -3 |